



Rotthäuser Str. 19
45879 Gelsenkirchen

Telephone +49 (209) 9242-0
Extension +49 (209) 9242-210
Telefax +49 (209) 9242-212
E-Mail a.koch@hyg.de
Internet www.hyg.de

Reference: **K-175000-09-Ko/st**
Contact person: Dr. Andreas Koch

Gelsenkirchen, 30.03.2009

TEST CERTIFICATE
according to the KTW-Recommendations
(Bundesgesundheitsblatt Vol. 20, page 124 ff., 1977)

Extension of validity (Ref.-No.: C-116434-04-Sf/st dated 16.04.2004)

Applicant:

Rich. Klinger
Dichtungstechnik GmbH & Co KG
Am Kanal 8-10
2352 Gumpoldskirchen
ÖSTERREICH

Product:

KLINGERSIL C-4400 (turquoise)

Kind of test:

☒ Product test / Permission test

☐ Supervision test

Test plates made of NBR-rubber compound **KLINGERSIL C-4400** (turquoise) meet the requirements of the KTW-recommendations part 1.3.13 according to the test report dated **16.04.2004**, Ref.-No.: **C-116434-04-Sf/st** for the following applications and temperatures:

Applications:

Temperatures:

	cold water (23°C)	moderately hot water (60°C)	extremely hot water (90°C)
A Pipes	---	---	---
B Reservoirs / Containers	---	---	---
C Ancillaries / Fittings	---	---	---
D1 large gaskets	passed	---	---
D2 small gaskets	passed	---	---

as far as the material is qualified technically.

This test certificate is ending by **16.04.2014**, as far as there are no changes in the formula.

The Director of the Institute
on behalf of

(Dr. rer. nat. A. Koch)
Head of the Dept. for water
hygienic material examinations



The results and conclusions exclusively refer to the investigated samples and the relevant laws.

The validity of this document expires in case of modifications in the composition of the product or the processing conditions.

This document must not be reproduced except in full, without our written approval.



DAP-PL-2548.00