



Rotthäuser Str. 19
45879 Gelsenkirchen

Phone (0209) 9242-0
Direct-Phone - 270
Telefax - 212
E-Mail k.stefanski@hyg.de
Internet www.hyg.de

Ref.: C-120408-04-Sf/st
Contact Person: Mrs. Stefanski

TEST CERTIFICATE
according to the KTW-Recommendations
(Bundesgesundheitsblatt Vol. 20, page 124 ff., 1977)

- Extension (Dir.Tgb.-No: C 1087/99/st) dated 23.06.1999 -

Applicant: KLINGER GmbH
Richard-Klinger-Str.

D-65510 Idstein
GERMANY

Product: sealant KLINGERSil C-4243

Kind of test: ☒ Producttest / Permissiontest ☐ Supervisiontest

The sealant KLINGERSil C-4243 meet the requirements of the KTW-Recommendations according to the test certificate (Dir.-Tgb.-No.: C 1087/99st dated 23.06.1999) for the following applications and temperatures:

Applications:

Temperatures:

| | cold water (23°C) | moderately hot water (60°C) | extremely hot water (90°C) |
|---------------------------|-------------------|-----------------------------|----------------------------|
| A Pipes | --- | --- | --- |
| B Reservoirs / Containers | --- | --- | --- |
| C Ancillaries / Fittings | --- | --- | --- |
| D1 large gaskets | --- | --- | --- |
| D2 small gaskets | passed | --- | --- |

as far as the material is qualified technically.

This test certificate ending by 23.06.2009, as far as there are no changes in the formula.

Gelsenkirchen, 26.08.2004



The Director of the Institute
on behalf of

(Dipl.-Chem. A. Koch)

Durch die DAP Deutsches Akkreditierungssystem Prüfwesen
GmbH akkreditiertes Prüflaboratorium
Die Akkreditierung gilt für die in der Urkunde
aufgeführten Prüfverfahren.

Deutscher Akkreditierungsrat
DAR
DAP-PL-2548.00

The test certificate shall not be reproduced except in full, without written approval of the Institute.

The test results refers to the specimen. This test certificate is no DVGW-Certification.

Träger des Hygiene-Instituts:
Verein zur Bekämpfung der Volkskrankheiten
im Ruhrkohlengebiet e.V., Gelsenkirchen