



Rich. Klinger Dichtungstechnik
GmbH & Co. KG
Am Kanal 8-10
2352 Gumpoldskirchen
ÖSTERREICH

Rotthäuser Str. 19
45879 Gelsenkirchen

Telephone (0209) 9242-0
Extension (0209) 9242-270
Telefax (0209) 9242-212
E-Mail k.stefanski@hyg.de
Internet www.hyg.de

Reference: C-138604-06-Sf/st
Contact person: Mrs. Stefanski

Gelsenkirchen, 20.04.2006

TEST CERTIFICATE according to the UBA-Guideline 2005

Product: sealing material **KLINGER® top-chem 2000** (grey)

Kind of test: ☒ Product test / Permission test ☐ Supervision test

Test plates made of sealing material **KLINGER® top-chem 2000** (grey) meet the requirements according to the test report dated **20.04.2006 (Ref.: C-138604-06-Sf/st)** for the following applications and temperatures:

Applications:	cold water	moderately hot water	extremely hot water
Pipes < DN 80 (in house)	---	---	---
Pipes 80 mm ≤ DN < DN 300 (distribution)	---	---	---
Pipes ≥ DN 300 (main trunks)	---	---	---
Ancillaries for pipes DN < 80 mm (in house)	---	---	---
Ancillaries for pipes 80 mm ≤ DN < 300 mm (in distribution piping system)	---	---	---
Ancillaries for pipes DN ≥ 300 mm (in main trunks)	---	---	---
Gaskets for pipes DN < 80 mm (in house)	passed	---	---
Gaskets for pipes 80 mm ≤ DN < 300 mm (in distribution piping system)	passed	---	---
Gaskets for pipes DN ≥ 300 mm (in main trunks)	passed	---	---
Reservoirs (in house) and repair systems for reservoirs	---	---	---
Reservoirs (distribution) and repair systems for reservoirs	---	---	---

as far as technically suited.

This test certificate is valid beginning with date of issue and ending by **20.04.2011** as far as there are no changes in the formula. After this time it can be extended for further 5 years if demanded.

The Director of the Institute
on behalf of

(Dr. rer. nat. A. Koch)



The results and conclusions exclusively refer to the investigated samples and the relevant laws.
The validity of this document expires in case of modifications in the composition of the product or the processing conditions.
This document must not be reproduced except in full, without our written approval.



DAP-PL-2548.00