



Rotthäuser Str. 19
45879 Gelsenkirchen

Telephone +49 (209) 9242-0
Extension +49 (209) 9242-210
Telefax +49 (209) 9242-212
E-Mail a.koch@hyg.de
Internet www.hyg.de

Ref.-No.: C-143531-06-Ko/ko
Contact-person: Mr. Dr. Koch

Gelsenkirchen, 26.09.2006

TEST CERTIFICATE
according to the KTW-Recommendations
(Bundesgesundheitsblatt Vol. 20, page 124 ff., 1977)

(English version dated 15.09.2006, Ref.-No.: C-143276-06-Ko/ko)

Applicant:

Rich. Klinger
Dichtungstechnik GmbH & Co KG
Am Kanal 8-10
2352 GUMPOLDSKIRCHEN
ÖSTERREICH

Product:

KLINGER® top-graph 2000 (grey)

Kind of test:

☒ Product test / Permission test

☐ Supervision test

The test plates made of rubber-material **KLINGER® top-graph 2000 (grey)** meet the requirements of the KTW-Recommendations according to the test report, dated **26.09.2006 (Ref.: C-143531-06-Ko/ko)** for the following applications and temperatures:

Applications:

Temperatures:

| | cold water | moderately hot water | extremely hot water |
|---------------------------|------------|----------------------|---------------------|
| A Pipes | --- | --- | --- |
| B Reservoirs / Containers | --- | --- | --- |
| C Ancillaries / Fittings | --- | --- | --- |
| D1 large gaskets | --- | --- | --- |
| D2 small gaskets | passed | --- | --- |

as far as the material is qualified technically.

This test certificate is valid beginning with date of issue and ending by **15.09.2011**, as far as there are no changes in the formula. After this time it can be extended for further 5 years if demanded.

The Director of the Institute
on behalf of

(Dr. rer. nat. A. Koch)



The results and conclusions exclusively refer to the investigated samples and the relevant laws.

The validity of this document expires in case of modifications in the composition of the product or the processing conditions.

This document must not be reproduced except in full, without our written approval.



DAP-PL-2548.00