

DVGW-Baumusterprüfzertifikat

DVGW type examination certificate

DG-5126BQ0167

Registriernummer
registration number

Anwendungsbereich <i>field of application</i>	Produkte der Gasversorgung <i>products of gas supply</i>
Zertifikatinhaber <i>owner of certificate</i>	Rich. Klinger Dichtungstechnik GmbH & Co KG Am Kanal 8-10, A-2352 Gumpoldskirchen
Vertreiber <i>distributor</i>	Rich. Klinger Dichtungstechnik GmbH & Co KG Am Kanal 8-10, A-2352 Gumpoldskirchen
Produktart <i>product category</i>	greasing and sealing materials: Flat sealing materials for gas installation, with higher thermal resistance (5126)
Produktbezeichnung <i>product description</i>	flat sealing material on synthetic fiber basis with higher thermal resistance
Modell <i>model</i>	KLINGERSil C4400
Prüfberichte <i>test reports</i>	laboratory control test: 08/137/5126/01 from 18.06.2008 (EBI)
Prüfgrundlagen <i>basis of type examination</i>	DVGW VP 401 (01.10.1998)

Ablaufdatum / AZ 31.05.2011 / 08-0200-GNV
date of expiry / file no.

11.07.2008 Rie A-1/2
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Akkreditierungsstelle Technik (DATech)
in der TGA GmbH akkreditiert für die Konformitätsbewertung von Produkten der
Gas- und Wasserversorgung

DVGW CERT GmbH - accredited by Deutsche Akkreditierungsstelle Technik
(DATech) in the TGA GmbH for conformity assessment of products of gas and
water supply



DAT-ZE-009/96-02

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

Typ	Technische Daten	Bemerkungen
<i>type</i>	<i>technical data</i>	<i>remarks</i>
C4400	pressure range: 1,0 bar	

Verwendungshinweise / Bemerkungen***hints of utilization / remarks***

application area: flanges in pressure regulators and gas meters according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN 1092-2

DVG